



Tabela regulacyjna od sezonu grzewczego 2010/2011
dla odbiorców zasilanych z ciepłowni w Międzyzlesiu

Temperatura zewnętrzna [°C]	Temperatura wody zasilającej [°C]	Temperatura wody powrotnej [°C]
+12	85	60
+11	85	
+10	85	
+9	86	62
+8	87	
+7	88	
+6	89	
+5	90	
+4	92	64
+3	93	
+2	94	
+1	95	
0	96	
-1	98	66
-2	100	
-3	102	
-4	103	
-5	105	
-6	106	68
-7	107	
-8	108	
-9	109	
-10	110	
-11	111	70
-12	112	
-13	113	
-14	115	
-15	116	
-16	117	
-17	119	
-18	120	
-19	121	
-20	122	