



Tabela regulacyjna wody sieciowej dla grupowych węzłów ciepłych
od sezonu 2010 / 2011

Temperatura zewnętrzna t_{zewn} [°C]	Współczynnik φ	Temperatura zasilania T_z [°C]	Temperatura powrotu T_p [°C]
12	0,20	68,0	44,5
11	0,23	68,5	44,5
10	0,25	69,0	44,5
9	0,28	69,0	44,5
8	0,30	69,5	44,5
7	0,33	70,0	44,5
6	0,35	70,5	45,0
5	0,38	73,0	45,5
4	0,40	75,0	45,9
3	0,43	78,0	46,3
2	0,45	80,5	46,8
1	0,48	81,8	47,2
0	0,50	83,1	47,6
-1	0,53	84,4	48,1
-2	0,55	85,7	48,5
-3	0,58	87,0	49,0
-4	0,60	89,0	49,5
-5	0,63	91,5	49,9
-6	0,65	93,0	50,3
-7	0,68	96,0	50,8
-8	0,70	98,0	51,2
-9	0,73	99,3	51,6
-10	0,75	100,6	52,1
-11	0,78	102,0	52,5
-12	0,80	104,0	53,0
-13	0,83	105,5	53,5
-14	0,85	107,0	54,0
-15	0,88	109,0	54,5
-16	0,90	110,0	55,0
-17	0,93	111,0	55,5
-18	0,95	112,0	56,0
-19	0,98	113,0	56,5
-20	1,00	114,0	57,0